

FIRE SAFETY CERTIFICATE

No. 1114 | 2025-26

Dated: 30-07-2025

Certified that the school **Late Shri Dhanrajji Mishrilalji Bhansali English Medium School.** (Name of the building or premises) At Neminagar, Chandwad, Dist. Nashik -423101.(address) comprised of No basement basement(s) and **one block Ground floor & Four Upper floors (Block 1, G+4)** (upper floors) owned/ occupied by **Late Shri Dhanrajji Mishrilalji Bhansali English Medium School.** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 30/07/2025 (date of inspection) in the presence of Manager Jadhav Siteshwari Rajendra & **Late Shri Dhanrajji Mishrilalji Bhansali English Medium School**, Neminagar, Chandwad Dist. Nashik -423101. Maharashtra State (name and addresses of the Manager/ Secretary or his **One year 30/07/2025 to 29/07/2026** in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 29/07/2025 (date of issue) At Neminagar, Chandwad, Dist. Nashik -423101. (place) by *Strike out whichever is not applicable.

अग्निशमन विभाग प्रमुख
Signature with Seal: मनमाड नगर परिषद मनमाड

Name : Tushar Patil

Designation : Fire officer

Name & Address of Department/ Office: Fire Department
Neminagar
parished

To

**The Principal
Late Shri Dhanrajji Mishrilalji
Bhansali English Medium School.
Neminagar, Chandwad, Dist. Nashik-423101**

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled an annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



This is to certify that a No Objection Certificate (NOC) for providing fire-fighting services from the Manmad Municipal Council office has been renewed for the SNJB's Late Shri Dhanraji Bhansali English Medium School building, located at Gut No. 714 and 717 in Neminagar, within the Chandwad city limits, owned by Shri Neminath Jain. This renewal is granted subject to the following terms and conditions, as a precautionary measure against fire.

Terms and Conditions:

1. Firefighting equipment, fire extinguisher system and a fire hydrant system phone, should be kept in the building, internal passage.
2. Keep both entry and exit routes open.
3. Construct a water tank or keep sufficient water in Sintex tanks 24 hours for immediate water availability.
4. Keep buckets filled with fire-resistant sand for emergency situations.
5. Display appropriate wall posters for emergency exits as a precautionary measure.
6. Do not store flammable materials in the office or building.
7. Roads (access and approach) should be wide enough for fire vehicles to access during emergencies.
8. Fire-resistant doors near staircases on each floor should be kept closed.
9. Do not use electrical appliances carelessly.
10. Use only one electrical appliance per plug point.
11. Papers, cupboards, racks, etc., in the room should not be placed close to electrical switchboards
12. The No Objection Certificate is issued only from the perspective of fire safety. The legality of the plot and construction will be confirmed only by the concerned department.
13. "As per the **Maharashtra Fire Prevention and Life Safety Act, 2006**, it is mandatory to have the necessary fire-fighting and prevention facilities readily available."
14. In multi-storey buildings, construct a water tank on each floor and install pipeline fittings from the first floor to the top floor for immediate water supply by the fire service in case of an emergency.
15. Your organization will be responsible for fire damages.
16. You will be entirely responsible for getting a fire audit conducted by a government-appointed fire agency and submitting the certificate (B-form) to the concerned Municipal Council twice a year.
17. The issued certificate will be valid for a period of one year from the date of issue.

This certificate is issued subject to the above conditions.

s/d

Chief Officer
Manmad Nagar Parishad

Seal

Dattu Devaram Zelte
Parties are identified by

Dattu Devaram Zelte
R/o. Chandwad Merhiz

BEFORE ME

10/06/2025
RAJENDRA P. THAKARE
Advocate & Notary Govt. of Maharashtra
Office : Somvar Peth, Chandwad,
Tal. Chandwad, Dist. Nashik
Pin - 423 101 Maharashtra



मनमाड नगरपरिषद मनमाड

ता. नांदगाव, जि. नाशिक



फोन नं. ०२५९१ - २२२३२८

Email - co.manmad@gmail.com

जा.क्र. / मनपा/ अग्निशमन /९९९४ / २०२५ - २६

दिनांक :- ४०/०४/ २०२५

अग्निशमन ना हरकत प्रमाणपत्र नूतनीकरण

विषय :- अग्निशमन ना हरकत प्रमाणपत्र मिळणेबाबत ...

संदर्भ :- आपले दिनांक १०/०७/२०२५ रोजीचे अर्ज.

प्रमाणपत्र देण्यात येते की, चांदवड शहर हृदीतील नेमिनगर येथिल गट नं. ७१४ & ७१७ मधील श्री. नेमिनाथ जैन यांचे मालकीचे "एसएनजेबीस स्व. श्री. धनराजजी भन्साळी इंग्लिश मिडीअम स्कूल" या इमारतीस आग लागू नये यासाठी खबरदारी उपाय म्हणुन मनमाड नगर परिषद कार्यालयाकडून अग्निशमन सेवा देण्याची सुविधा उपलब्ध करणेबाबत खालील अटी - शर्तीस अधीन राहून ना हरकत प्रमाणपत्र नूतनीकरण करून देण्यात येत आहे.

अटी व शर्ती :-

१. इमारतीमध्ये, आतल्या मोकळ्या (Passage) चे जागेत फायर फायटिंगचे साधने, Fire Extinguisher System व हायड्रेट सिस्टम फोन ठेवणे बंधनकारक राहील.
२. दोन्ही बाजूने येण्या - जाण्याचा मार्ग खुला ठेवणे बंधनकारक राहील.
३. पाणी त्वरीत उपलब्ध व्हावे म्हणुन हौद बांधणे किंवा सिन्टेक्स टाक्यात २४ तास पुरेशा प्रमाणात पाणी ठेवणे बंधनकारक राहील.
४. आग विरोधी वाळूने भरलेल्या बादल्या आपात्कालीन परिस्थितीसाठी भरून ठेवणे बंधनकारक राहील.
५. खबरदारी म्हणुन बाहेर पडण्यासाठी योग्य ती भिंती पत्रके लावणे.
६. ज्वलनशील पदार्थ कार्यालयात किंवा बिल्डींगच्या आवारात ठेऊ नये.
७. आपात्कालीन काळात अग्निशमन वाहने येऊ शकतील इतक्या रुंदीचे (Access and Approach) रस्ते असावेत.
८. मजल्यावरील मार्गातील जिन्याजवळील अग्निरोधक दरवाजे बंद करावे.
९. विद्युत उपकरणाचा निष्काळजीपणे वापर करू नये.
१०. विजेच्या प्लगवर एक विद्युत यंत्राचा वापर करावा.
११. कक्षातील कागदपत्रे, कपाटे, मांडणी, इत्यादी विद्युत स्वीच बोर्डला चिकटून ठेऊ नये.
१२. ना - हरकत प्रमाणपत्र केवळ अग्निशमन सुरक्षतेचा दृष्टिकोनातून जारी केला आहे, प्लॉट आणि बांधकाम च्या कायदेशीर पणाची फक्त संबंधित विभाककडून पृष्ठी केली जाईल.
१३. महाराष्ट्र अग्निविरोधक आणि जीवन सुरक्षा अधिनियम - २००६ नुसार आवश्यक अग्निशमन प्रतिबंधक सुविधा उपलब्ध करून ठेवणे बंधनकारक राहील.
१४. बहुमजली इमारतीवर प्रत्येक मजल्यावर पाण्याचा हौद बांधणे व आपात्कालीन परिस्थितीत अग्निशमन सेवा मार्फत त्वरीत पाणीपुरवठा व्हावा म्हणुन पहिल्या मजल्यापासून ते शेवटच्या मजल्यापर्यंत पाईपलाईन फिटींगकरणे बंधनकारक राहील.
१५. आग नुकसानी बाबतची जबाबदारी आपली स्वतःची राहील.

(P.T.O.)

(२)

१६. शासनाने नेमून दिलेल्या फायर एजन्सी कडून फायर ऑडीट करून प्रमाणपत्र (B-फॉर्म) वर्षात २ वेळा संबंधित नगरपरिषदेस सादर करावयाची सर्वस्वी जबाबदारी आपली राहील.
१७. सदरील प्रमाणपत्रांची मुदत दिलेल्या तारखेपासून ०१ वर्ष पर्यंत वैध राहील.

वरील अटीस अधीन राहून अग्निशन ना हरकत प्रमाणपत्र देण्यात येत आहे.



१

मुख्याधिकारी

मनमाड नगरपरिषद मनमाड

A handwritten signature in blue ink, appearing to read "मनमाड नगरपरिषद" followed by a date.